

Certificate of Performance

on this date the Cleanroom Facilities of

C2C Development

Softwall Cleanroom

have been tested in accordance with NEBB Procedural Standards
For Certified Testing of Cleanrooms to meet the following air cleanliness level
requirements of ISO 14644-1:2015 for an AT REST cleanroom.

ISO Class 7 @ 0.5 & 5.0 μm - Softwall Cleanroom

MFI Job #: AB12906-1

Micro FILTRATIONS, INC.

112 N. Poplar Ave. Sanford, FL 32771

(407) 682-0070

Signature: *F. Les Miller*

F. Les Miller

NEBB CPT Certified Professional

29 June 2021

