

CERTIFICATE OF COMPLIANCE

Project Name: C2C Development LLC

Conducted: 18 March 2024 through 19 March 2025

Certification Number: A6000578

Test Occupancy State: AT-REST

Considered Particle Sizes: 0.5 µm and 5.0 µm

Room Designation	Classification	Room Designation	Classification	Room Designation	Classification
Cleanroom A	ISO Class 7	N/A	N/A	NIA	N/A
Changing Room B/C	ISO Class 7	N/A	N/A	N/A	N/A
Cleanroom B	ISO Class 7	N/A	N/A	N/A	N/A
Cleanroom C	ISO Class 7	NIA	N/A	N/A	NIA
N/A	NIA	N/A	N/A	N/A	NIA
NIA	N/A	NIA	N/A	N/A	N/A
N/A	N/A	N/A	N/A	N/A	N/A

Technical Maintenance Incorporated hereby certifies that the listed cleanroom and/or suite(s) was tested in accordance with the requirements of ISO 14644-1 :2015(E), ISO 14644-2:2015(E), ISO 14644-3:2005(E), IEST-RP-CC-006.3, NEBB Procedural Standards for Certified Testing of Cleanrooms, Technical Maintenance Inc. SOP-26, and customer specific requirements.

Timothy Walsh

Schuyler Cournoyer

Certified By: Timothy Walsh

Reviewed by: Schuyler Cournoyer

Date: 19 March 2025

Certification Expiry Date: 19 March 2026

THE DATA PRESENTED IN THIS REPORT IS A RECORD OF CLEANROOM AND SYSTEM PERFORMANCE AND WAS OBTAINED IN ACCORDANCE WITH THE CURRENT EDITION OF THE NEBB PROCEDURAL STANDARDS FOR CERTIFIED TESTING OF CLEANROOMS, AND APPROPRIATE STANDARDS. ANY VARIANCES FROM DESIGN, SPECIFIED, OR AGREED TO CRITERIA ARE NOTED IN THE CLEANROOM REPORT PROJECT SUMMARY.

the most advanced
calibration & testing laboratory...



CERTIFICATE OF COMPLIANCE

Project Name: C2C Development LLC
Conducted: 18 March 2024 through 19 March 2025
Certification Number: A6001350
Test Occupancy State: AT-REST

Considered Particle Sizes: 0.5 µm and 5.0 µm

Room Designation	Classification	Room Designation	Classification	Room Designation	Classification
Poseidon Gowning Room	ISO Class 7	N/A	N/A	N/A	N/A
Poseidon Cleanroom	ISO Class 7	N/A	N/A	N/A	N/A
N/A	N/A	N/A	N/A	N/A	N/A
N/A	N/A	N/A	N/A	N/A	N/A
N/A	N/A	N/A	N/A	N/A	N/A
N/A	N/A	N/A	N/A	N/A	N/A
N/A	N/A	N/A	N/A	N/A	N/A

Technical Maintenance Incorporated hereby certifies that the listed cleanroom and/or suite(s) was tested in accordance with the requirements of ISO 14644-1:2015(E), ISO 14644-2:2015(E), ISO 14644-3:2005(E), IEST-RP-CC-006.3, NEBB Procedural Standards for Certified Testing of Cleanrooms, Technical Maintenance Inc. SOP-26, and customer specific requirements.

Timothy Walsh

Schuyler Cournoyer

Certified By: Timothy Walsh

Reviewed by: Schuyler Cournoyer

Date: 19 March 2025

Certification Expiry Date: 19 March 2026

THE DATA PRESENTED IN THIS REPORT IS A RECORD OF CLEANROOM AND SYSTEM PERFORMANCE AND WAS OBTAINED IN ACCORDANCE WITH THE CURRENT EDITION OF THE NEBB PROCEDURAL STANDARDS FOR CERTIFIED TESTING OF CLEANROOMS, AND APPROPRIATE STANDARDS. ANY VARIANCES FROM DESIGN, SPECIFIED, OR AGREED TO CRITERIA ARE NOTED IN THE CLEANROOM REPORT PROJECT SUMMARY.

TECHNICAL MAINTENANCE INC.
3060 VENTURE LANE, STE 105 MELBOURNE, FL 32934
WWW.TMICALIBRATION.COM